

WATER QUALITY REPORT
PEU/HARVEST VILLAGE, LONDONDERRY, NH
EPA # 1392290

VOLATILE ORGANIC CONTAMINANTS (b) (Units µg/L)

Analyte	Results	MCL	Date	Analyte	Results	MCL	Date
1,1,1,2-Tetrachloroethane	< 0.5	NR	7/14/25	Chloroform	< 0.5	80	7/14/25
1,1,1-Trichloroethane	< 0.5	200	7/14/25	Chloromethane	< 0.5	NR	7/14/25
1,1,2,2-Tetrachloroethane	< 0.5	NR	7/14/25	cis-1, 2-Dichloroethylene	< 0.5	70	7/14/25
1,1,2-Trichloroethane	< 0.5	5	7/14/25	cis-1, 3-Dichloropropylene	< 0.5	NR	7/14/25
1,1-Dichloroethane	< 0.5	NR	7/14/25	Dibromochloromethane	0.8	80	7/14/25
1,1-Dichloroethylene	< 0.5	7	7/14/25	Dibromomethane	< 0.5	NR	7/14/25
1,1-Dichloropropylene	< 0.5	NR	7/14/25	Dichlorodifluoromethane	< 0.5	NR	7/14/25
1,2,3-Trichlorobenzene	< 0.5	NR	7/14/25	Diethyl ether	< 0.5	NR	7/14/25
1,2,3-Trichloropropane	< 0.5	NR	7/14/25	Diisopropyl Ether (DIPE)	< 0.5	NR	7/14/25
1,2,4-Trichlorobenzene	< 0.5	70	7/14/25	Ethyl Tert-Butyl Ether (ETBE)	< 0.5	NR	7/14/25
1,2,4-Trimethylbenzene	< 0.5	NR	7/14/25	Ethylbenzene	< 0.5	700	7/14/25
1,2-Dibromo - 3- chloropropane	< 0.5	0.2	7/14/25	Hexachlorobutadiene	< 0.5	NR	7/14/25
1,2-Dibromoethane	< 0.5	NR	7/14/25	Isopropylbenzene	< 0.5	NR	7/14/25
1,2-Dichlorobenzene	< 0.5	600	7/14/25	m&p - Xylenes	<1	NR	7/14/25
1,2-Dichloroethane	< 0.5	5	7/14/25	Methylene chloride	< 0.5	5	7/14/25
1,2-Dichloropropane	< 0.5	5	7/14/25	Methyl-t-butyl-ether (MtBE)	< 0.5	13	7/14/25
1,3,5-Trimethylbenzene	< 0.5	NR	7/14/25	Napthalene	< 0.5	NR	7/14/25
1,3-Dichlorobenzene	< 0.5	NR	7/14/25	n-Butylbenzene	< 0.5	NR	7/14/25
1,3-Dichloropropane	< 0.5	NR	7/14/25	Nitrobenzene	<10	NR	7/13/23
1,4-Dichlorobenzene	< 0.5	75	7/14/25	n-Propylbenzene	< 0.5	NR	7/14/25
2,2-Dichloropropane	< 0.5	NR	7/14/25	o-Xylene	< 0.5	NR	7/14/25
2-Butanone (MEK)	<10	NR	7/20/17	sec Butylbenzene	< 0.5	NR	7/14/25
2-Chlorotoluene	<0.5	0.5	7/14/25	Styrene	< 0.5	100	7/14/25
2-Hexanone	<10	NR	7/20/17	Tert-Amyl Methyl Ether (TAME)	< 0.5	NR	7/14/25
4 Methyl-2-Pentanone (MIBK)	<10	NR	7/20/17	Tert-Butyl Alcohol (TBA)	<10	NR	7/14/25
4-Chlorotoluene	<0.5	0.5	7/14/25	Tert-Butylbenzene	< 0.5	NR	7/14/25
4-Isopropyltoluene	< 0.5	NR	7/14/25	Tetrachloroethylene	< 0.5	5	7/14/25
Acetone	<10	NR	7/20/17	Tetrahydrofuran	<10	NR	7/14/25
Benzene	< 0.5	5	7/14/25	Toluene	< 0.5	1000	7/14/25
Bromobenzene	< 0.5	NR	7/14/25	Total Trihalomethanes	1.5	80	7/14/25
Bromochloromethane	< 0.5	NR	7/14/25	Total Xylenes	< 0.5	10,000	7/14/25
Bromodichloromethane	<0.5	80	7/14/25	Trans-1, 2-Dichloroethylene	< 0.5	100	7/14/25
Bromoform	0.7	80	7/14/25	Trans-1, 3-Dichloropropylene	< 0.5	NR	7/14/25
Bromomethane	< 0.5	NR	7/14/25	Trichloroethylene	< 0.5	5	7/14/25
Carbon Disulfide	< 0.5	NR	7/14/25	Trichlorofluoromethane	< 0.5	NR	7/14/25
Carbon Tetrachloride	< 0.5	5	7/14/25	Vinyl chloride	< 0.5	2	7/14/25
Chlorobenzene	< 0.5	100	7/14/25				
Chloroethane	<0.5	NR	7/14/25				

SYNTHETIC ORGANIC CONTAMINANTS (b) (Units µg/L)

Analyte	Results	MCL	Date	Analyte	Results	MCL	Date
2,4,5-TP (Silvex)	< 0.25	50	7/9/25	Glyphosate	< 10	700	7/9/25
2,4-D	< 1	70	7/9/25	Heptachlor	< 0.1	0.4	7/9/25
3-Hydroxycarbofuran	< 1	NR	7/9/25	Heptachlor Epoxide	< 0.1	0.2	7/9/25
Alachlor	< 0.1	2	7/9/25	Hexachlorobenzene	< 0.1	1	7/9/25
Aldicarb	< 1	NR	7/9/25	Hexachlorocyclopentadiene	< 0.1	50	7/9/25
Aldicarb Sulfone	< 1	NR	7/9/25	Lindane	< 0.1	0.2	7/9/25
Aldicarb Sulfoxide	< 1	NR	7/9/25	Methiocarb	< 1	7	7/9/25
Aldrin	< 0.1	NR	7/9/25	Methomyl	< 1	NR	7/9/25

WATER QUALITY REPORT
PEU/HARVEST VILLAGE, LONDONDERRY, NH
EPA # 1392290

Atrazine	< 0.1	3	7/9/25
Benzo(a)pyrene	< 0.1	0.2	7/9/25
Butachlor	< 0.1	NR	7/9/25
Carbaryl	< 1	NR	7/9/25
Carbofuran	< 1	40	7/9/25
Chlordane	< 0.4	2	7/9/25
Dalapon	< 1	200	7/9/25
Di (2-ethylhexyl) adipate	< 1	400	7/9/25
Di (2-Ethylhexyl) phthalate	< 1	6	7/9/25
Dibromochloropropane (DBCP)	< 0.02	0.2	7/20/17
Dicamba	< 0.5	NR	7/9/25
Dieldrin	< 0.1	NR	7/9/25
Dinoseb	< 1	7	7/9/25
Diquat	< 1	20	7/9/25
Endrin	< 0.1	2	7/9/25
Ethylene dibromide (EDB)	< 0.02	0.05	7/9/25

Methoxychlor	< 0.1	40	7/9/25
Metolachlor	< 0.1	40	7/9/25
Metribuzin	< 0.1	NR	7/9/25
Oxamyl (Vydate)	< 1	200	7/9/25
PCB Aroclor 1016	< 0.08	NR	7/9/25
PCB Aroclor 1221	< 0.08	NR	7/9/25
PCB Aroclor 1232	< 0.08	NR	7/9/25
PCB Aroclor 1242	< 0.08	NR	7/9/25
PCB Aroclor 1248	< 0.08	NR	7/9/25
PCB Aroclor 1254	< 0.08	NR	7/9/25
PCB Aroclor 1260	< 0.08	NR	7/9/25
Pentachlorophenol	< 0.1	1	7/9/25
Picloram	< 2	500	7/9/25
Propachlor	< 0.1	NR	7/9/25
Propoxur (Baygon)	< 1	NR	7/9/25
Simazine	< 0.1	4	7/9/25
Toxaphene	< 2	3	7/9/25

RADIOLOGICAL CONTAMINANTS (b)

Analyte (Units)	Results	MCL	Date
Compliance Gross Alpha (pCi/L)	< 3	15	8/2/24
Radium 226 & 228 (pCi/L)	< 1	5	8/5/24
Uranium (µg/L)	< 1	30	7/22/24

FIRST DRAW LEAD AND COPPER (a)

Analyte	Results	AL	Date
Lead (µg/L) 90th percentile sample	0.002	15	4/12/2023
Copper (mg/L) 90th percentile sample	0.157	1.3	4/12/2023

WATER QUALITY REPORT
PEU/HARVEST VILLAGE, LONDONDERRY, NH
EPA # 1392290

INORGANIC CONTAMINANTS (b)

Analyte	Results	MCL	Date
Antimony (mg/L)	<0.001	0.006	7/9/25
Arsenic (mg/L)	0.003	0.01	7/9/25
Barium (mg/L)	0.0028	2	7/9/25
Beryllium (mg/L)	<0.001	0.004	7/9/25
Cadmium (mg/L)	<0.001	0.005	7/9/25
Chromium (mg/L)	<0.001	0.1	7/9/25
Fluoride (mg/L)	0.89	4	7/9/25
Mercury (mg/L)	<0.0001	0.002	7/9/25
Nitrate-N (mg/L)	1.44	10	7/9/25
Nitrite-N (mg/L)	< 0.2	1	8/2/24
Selenium (mg/L)	<0.001	0.05	7/9/25
Thallium (mg/L)	<0.001	0.002	7/9/25
Cyanide (mg/L)	<0.005	0.2	7/9/25

SECONDARY CONTAMINANTS (b) - AESTHETIC

Analyte	Results	SMCL	Date
Chloride (mg/L)	35	NR	7/9/25
Fluoride (mg/L)	0.89	2	7/9/25
Iron (mg/L)	0.022	0.3	7/9/25
Manganese (mg/L)	0.0019	0.05	7/9/25
pH (Standard Units)	7.19	6.5 – 8.5	7/9/25
Sulfate (mg/L)	25	250	7/9/25
Zinc (mg/L)	0.0119	5	7/9/25

Microbiological Contaminants (a)

Microbiological Contaminants (a)	Results	MCL	Frequency
Total Coliform	Absent	≤ 1/month	Monthly
E. coli	Absent	Absent	Monthly
Chlorine Residual Range (mg/L)	0.2 - 1.0		

DISINFECTION BY-PRODUCTS (a)

Total Trihalomethanes (µg/L)	2.7	80	7/16/25
Haloacetic Acids (µg/L)	<1	60	7/16/25

UNREGULATED CONTAMINANTS (b)

Analyte (Units)	Results	Date
Alkalinity as CaCO ₃ (mg/L)	97	7/9/25
Calcium (mg/L)	38	7/9/25
Copper (mg/L)	0.012	7/9/25
Hardness, Total as CaCO ₃ (mg/L)	106	7/9/25
Magnesium (mg/L)	2.6	7/9/25
Nickel (µg/L)	<0.001	7/9/25
Radon Gas (pCi/L)	1022	4/11/23
Sodium (mg/L)	84.6	7/9/25

Perfluorinated Chemicals (PFCs)

Analyte (Units)	Results	MCL	Date
Hexafluoropropylene oxide dimer acid (HFPO-DA)	<2.00	NR	10/15/25
Perfluorobutanesulfonic acid (PFBS)	<2.00	NR	10/15/25
Perfluorohexanesulfonic acid (PFHxS) (ng/L)	<2.00	18	10/15/25
Perfluorononanoic acid (PFNA) (ng/L)	<2.00	11	10/15/25
Perfluorooctanesulfonic Acid (PFOS)	<2.00	15	10/15/25
Perfluorooctanoic acid (PFOA)	<2.00	12	10/15/25

SOURCE WATER AND TREATMENT INFORMATION

Water Source: Two bedrock wells

Treatment: Treatment consists of an ion exchange unit for reducing hardness, resin specific media to remove PFCs, and chlorination to disinfectant.

KEY TO ABBREVIATIONS

AL Action Level - The concentration of a contaminant which, if exceeded triggers treatment of or other requirements which a water system must follow.

MCL Maximum Contaminant Level - The highest level of a contaminant that is allowed in drinking water.

SMCL Secondary Maximum Contaminant Level – These standards are developed to protect the aesthetic qualities of drinking water and are not health based characteristics (taste, odor, or color) of drinking water.

NR Not Regulated - Contaminants test for but not regulated by the State or EPA.

(a) samples taken from the distribution system.

(b) samples taken from the distribution entry point.

mg/L milligrams per Liter or parts per million.

µg/L micrograms per Liter or parts per billion.

ng/L nanograms per Liter or parts per trillion.

pCi/L picocuries per Liter (measure of radioactivity)

N/A Not Applicable **nd** not detected **BDL** Below Detection Level ≤ Less Than or Equal To < Less Than

CONTACT INFORMATION

If you have any questions about this report, or about your water quality, please call Matthew Day, Water Supply Manager, at 1-603-913-2377 or 1-800-553-5101

WATER QUALITY REPORT
PEU/HARVEST VILLAGE, LONDONDERRY, NH
EPA # 1392290

003-913-2377 or 1-800-333-5191.

Visit the State's website for Harvest Village:

<https://www4.des.state.nh.us/DWGBSamplingForms/FormsMenu.aspx?PWSID=1392290>

Additional information about contaminants and their potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline 1-800-426-4791.