

WATER QUALITY REPORT
Pioneer Commerce Park, Atkinson, NH
EPA # 0116010

VOLATILE ORGANIC CONTAMINANTS (b) (Units µg/L)

Analyte	Results	MCL	Date	Analyte	Results	MCL	Date
1,1,1,2-Tetrachloroethane	< 0.5	NR	10/20/25	cis-1, 2-Dichloroethylene	< 0.5	NR	10/20/25
1,1,1-Trichloroethane	< 0.5	NR	10/20/25	cis-1, 3-Dichloropropylene	< 0.5	NR	10/20/25
1,1,1,2,2-Tetrachloroethane	< 0.5	NR	10/20/25	Dibromochloromethane	5.7	NR	10/20/25
1,1,2-Trichloroethane	< 0.5	NR	10/20/25	Dibromomethane	< 0.5	NR	10/20/25
1,1-Dichloroethane	< 0.5	NR	10/20/25	Dichlorodifluoromethane	< 0.5	NR	10/20/25
1,1-Dichloroethylene	< 0.5	NR	10/20/25	Diethyl ether	< 0.5	NR	10/20/25
1,1-Dichloropropylene	< 0.5	NR	10/20/25	Diisopropyl Ether (DIPE)	< 0.5	NR	10/20/25
1,2,3-Trichlorobenzene	< 0.5	NR	10/4/23	Ethyl Tert-Butyl Ether (ETBE)	< 0.5	NR	10/14/24
1,2,3-Trichloropropane	< 0.5	NR	10/20/25	Ethylbenzene	< 0.5	NR	10/20/25
1,2,4-Trichlorobenzene	< 0.5	NR	10/20/25	Hexachlorobutadiene	< 0.5	NR	10/20/25
1,2,4-Trimethylbenzene	< 0.5	NR	10/20/25	Isopropylbenzene	< 0.5	NR	10/20/25
1,2-Dibromo - 3- chloropropane	< 0.5	NR	10/20/25	m/p - Xylenes	<1	NR	10/20/25
1,2-Dibromoethane	< 0.5	NR	10/20/25	Methylene chloride	< 0.5	NR	10/20/25
1,2-Dichlorobenzene	< 0.5	NR	10/20/25	Methyl-t-butyl-ether (MtBE)	< 0.5	NR	10/20/25
1,2-Dichloroethane	< 0.5	NR	10/20/25	Napthalene	< 0.5	NR	10/20/25
1,2-Dichloropropane	< 0.5	NR	10/14/24	n-Butylbenzene	< 0.5	NR	10/14/24
1,3,5-Trimethylbenzene	< 0.5	NR	10/20/25	n-Propylbenzene	< 0.5	NR	10/20/25
1,3-Dichlorobenzene	< 0.5	NR	10/20/25	o-Xylene	< 0.5	NR	10/20/25
1,3-Dichloropropane	< 0.5	NR	10/20/25	sec Butylbenzene	< 0.5	NR	10/20/25
1,4-Dichlorobenzene	< 0.5	NR	10/20/25	Styrene	< 0.5	NR	10/20/25
2-Chlorotoluene	<0.5	NR	10/20/25	Tert-Amyl Methyl Ether (TAME)	< 0.5	NR	10/20/25
4-Chlorotoluene	<0.5	NR	10/20/25	Tert-Butyl Alcohol (TBA)	<10	NR	10/20/25
4-Isopropyltoluene	< 0.5	NR	10/20/25	Tert-Butylbenzene	< 0.5	NR	10/20/25
Benzene	< 0.5	NR	10/14/24	Tetrachloroethylene	< 0.5	NR	10/14/24
Bromobenzene	< 0.5	NR	10/20/25	Tetrahydrofuran	<10	NR	10/20/25
Bromochloromethane	< 0.5	NR	10/20/25	Toluene	< 0.5	NR	10/20/25
Bromodichloromethane	8	NR	10/20/25	Total Trihalomethanes	22	NR	10/20/25
Bromoform	0.6	NR	10/20/25	Total Xylenes	< 0.5	NR	10/20/25
Bromomethane	< 0.5	NR	10/20/25	Trans-1, 2-Dichloroethylene	< 0.5	NR	10/20/25
Carbon Disulfide	< 0.5	NR	10/20/25	Trans-1, 3-Dichloropropylene	< 0.5	NR	10/20/25
Carbon Tetrachloride	< 0.5	NR	10/20/25	Trichloroethylene	< 0.5	NR	10/20/25
Chlorobenzene	< 0.5	NR	10/14/24	Trichlorofluoromethane	< 0.5	NR	10/14/24
Chloroform	8.1	NR	10/20/25	Vinyl chloride	< 0.5	NR	10/20/25
Chloromethane	< 0.5	NR	10/20/25				

SYNTHETIC ORGANIC CONTAMINANTS (b) (Units µg/L)

	Results	MCL	Date		Results	MCL	Date
2,4,5-TP (Silvex)	< 0.25	50	10/20/25	Heptachlor	< 0.1	0.4	10/20/25
2,4-D	< 1	70	10/20/25	Heptachlor Epoxide	< 0.1	0.2	10/20/25
3-Hydroxycarbofuran	< 1	NR	10/20/25	Hexachlorobenzene	< 0.1	1	10/20/25
Alachlor	< 0.08	2	10/20/25	Hexachlorocyclopentadiene	< 0.1	50	10/20/25
Aldicarb	< 1	3	10/20/25	Lindane	< 0.1	0.2	10/20/25
Aldicarb Sulfone	< 1	2	10/20/25	Methiocarb	< 1	NR	10/20/25
Aldicarb Sulfoxide	< 1	4	10/20/25	Methomyl	< 1	NR	10/20/25
Aldrin	< 0.1	NR	10/20/25	Methoxychlor	< 0.1	40	10/20/25
Atrazine	< 0.1	3	10/20/25	Metolachlor	< 0.1	NR	10/20/25
Benzo(a)pyrene	< 0.1	0.2	10/20/25	Metribuzin	< 0.1	NR	10/20/25
Butachlor	< 0.1	NR	10/20/25	Oxamyl (Vydate)	< 1	200	10/20/25

WATER QUALITY REPORT
Pioneer Commerce Park, Atkinson, NH
EPA # 0116010

Carbaryl	< 1	NR	10/20/25	PCB Aroclor 1016	<0.08	NR	10/20/25
Carbofuran	< 1	40	10/20/25	PCB Aroclor 1221	<0.08	NR	10/20/25
Chlordane	< 0.4	2	10/20/25	PCB Aroclor 1232	<0.08	NR	10/20/25
Dalapon	<1	200	10/20/25	PCB Aroclor 1242	<0.08	NR	10/20/25
Di (2-ethylhexyl) adipate	< 1	400	10/20/25	PCB Aroclor 1248	<0.08	NR	10/20/25
Di (2-Ethylhexyl) phthalate	< 1	6	10/20/25	PCB Aroclor 1254	<0.08	NR	10/20/25
Dicamba	< 0.5	NR	10/20/25	PCB Aroclor 1260	<0.08	NR	10/20/25
Dieldrin	< 0.1	NR	10/20/25	Pentachlorophenol	< 0.1	1	10/20/25
Dinoseb	< 1	7	10/20/25	Picloram	<2	500	10/20/25
Diquat	<1	NR	10/20/25	Propachlor	< 0.1	NR	10/20/25
Endrin	< 0.1	2	10/20/25	Propoxur (Baygon)	< 1	NR	10/20/25
Ethylene dibromide (EDB)	< 0.02	0.05	10/20/25	Simazine	< 0.1	4	10/20/25
Glyphosate	< 10	700	10/20/25	Toxaphene	< 2	3	10/20/25

RADIOLOGICAL CONTAMINANTS (b)

Analyte (Units)	Results	MCL	Date
Compliance Gross Alpha (pCi/L)	11	15	8/26/08
Radium 226 & 228 (pCi/L)	1.5	5	8/26/08
Uranium (µg/L)	0.54	30	8/26/08

FIRST DRAW LEAD AND COPPER (a)

Analyte	Results	AL	Date
Lead (µg/L) 90th percentile sample	0.001	15	10/30/2024
Copper (mg/L) 90th percentile sample	0.247	1.3	10/30/2024

WATER QUALITY REPORT
Pioneer Commerce Park, Atkinson, NH
EPA # 0116010

INORGANIC CONTAMINANTS (b)

Analyte	Results	MCL	Date
Antimony (mg/L)	<0.001	0.006	10/13/25
Arsenic (mg/L)	0.0011	0.01	10/13/25
Barium (mg/L)	0.0282	2	10/13/25
Beryllium (mg/L)	<0.001	0.004	10/13/25
Cadmium (mg/L)	<0.001	0.005	10/13/25
Chromium (mg/L)	<0.001	0.1	10/13/25
Fluoride (mg/L)	<0.2	4	10/13/25
Mercury (mg/L)	<0.0001	0.002	10/13/25
Nitrate-N (mg/L)	< 0.2	10	10/13/25
Nitrite-N (mg/L)	< 0.2	1	10/13/25
Selenium (mg/L)	<0.001	0.05	10/13/25
Thallium (mg/L)	<0.001	0.002	10/13/25
Cyanide (mg/L)	<0.005	0.2	10/13/25

SECONDARY CONTAMINANTS (b) - AESTHETIC

Analyte	Results	SMCL	Date
Chloride (mg/L)	130	250	10/13/25
Fluoride (mg/L)	<0.2	2	10/13/25
Iron (mg/L)	0.051	0.3	10/13/25
Manganese (mg/L)	0.088	0.05	10/13/25
pH (Standard Units)	7.27	6.5 – 8.5	10/13/25
Sulfate (mg/L)	23	250	10/13/25
Zinc (mg/L)	0.0101	5	10/13/25

Microbiological Contaminants (a)

Microbiological Contaminants (a)	Results	MCL	Frequency
Total Coliform	Absent	≤ 1/month	Monthly
E. coli	Absent	Absent	Monthly
Chlorine Residual Range (mg/L)	0.2 - 1.0		

DISINFECTION BY-PRODUCTS (a)

Analyte	Results	MCL	Date
Total Trihalomethanes (µg/L)	30	80	7/3/25
Haloacetic Acids (µg/L)	9.2	60	7/3/25

UNREGULATED CONTAMINANTS (b)

Analyte (Units)	Results	Date
Alkalinity as CaCO ₃ (mg/L)	100	10/13/25
Calcium (mg/L)	65.5	10/13/25
Copper (mg/L)	<0.001	10/13/25
Hardness, Total as CaCO ₃ (mg/L)	212	10/13/25
Magnesium (mg/L)	11.8	10/13/25
Nickel (µg/L)	<0.001	10/13/25
Radon Gas (pCi/L)	309	4/5/21
Sodium (mg/L)	30.7	10/13/25

Perfluorinated Chemicals (PFCs)

Analyte (Units)	Results	MCL	Date
Hexafluoropropylene oxide dimer acid (HFPO-DA) (ng/L)	<2.00	NR	10/13/25
Perfluorobutanesulfonic acid (PFBS) (ng/L)	2.36	NR	10/13/25
Perfluorohexanesulfonic acid (PFHxS) (ng/L)	0.845	18	10/13/25
Perfluorononanoic acid (PFNA) (ng/L)	<2.00	11	10/13/25
Perfluorooctanesulfonic acid (PFOS) (ng/L)	1.12	15	10/13/25
Perfluorooctanoic acid (PFOA) (ng/L)	2.95	12	10/13/25

SOURCE WATER AND TREATMENT INFORMATION

Water Source: One bedrock well.
Treatment: Chlorination

KEY TO ABBREVIATIONS

AL Action Level - The concentration of a contaminant which, if exceeded triggers treatment of or other requirements which a water system must follow.
MCL Maximum Contaminant Level - The highest level of a contaminant that is allowed in drinking water.
SMCL Secondary Maximum Contaminant Level – These standards are developed to protect the aesthetic qualities of drinking water and are not health based characteristics (taste, odor, or color) of drinking water.
NR Not Regulated - Contaminants test for but not regulated by the State or EPA.
(a) samples taken from the distribution system.
(b) samples taken from the distribution entry point.
mg/L milligrams per Liter or parts per million.
µg/L micrograms per Liter or parts per billion.
ng/L nanograms per Liter or parts per trillion.
pCi/L picocuries per Liter (measure of radioactivity)
N/A Not Applicable **nd** not detected **BDL** Below Detection Level ≤ Less Than or Equal To < Less Than

CONTACT INFORMATION

If you have any questions about this report, or about your water quality, please call Matthew Day, Water Supply Manager, at 1-603-913-2377 or 1-800-553-5191.

Visit the state website for the Pioneer Commerce Park system at
<https://www4.des.state.nh.us/DESOneStop/PWSDetail.aspx?ID=0116010>

WATER QUALITY REPORT
Pioneer Commerce Park, Atkinson, NH
EPA # 0116010

Additional information about contaminants and their potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline 1-800-426-4791.