

WATER QUALITY REPORT

Sweet Hill, Plaistow, NH

EPA # 1932200

VOLATILE ORGANIC CONTAMINANTS (b) (Units µg/L)

Analyte	Results	MCL	Date	Analyte	Results	MCL	Date
1,1,1,2-Tetrachloroethane	< 0.5	NR	7/18/24	Chloroform	17	80	7/18/24
1,1,1-Trichloroethane	< 0.5	200	7/18/24	Chloromethane	< 0.5	NR	7/18/24
1,1,2,2-Tetrachloroethane	< 0.5	NR	7/18/24	cis-1, 2-Dichloroethylene	< 0.5	70	7/18/24
1,1,2-Trichloroethane	< 0.5	5	7/18/24	cis-1, 3-Dichloropropylene	< 0.5	NR	7/18/24
1,1-Dichloroethane	< 0.5	NR	7/18/24	Dibromochloromethane	1.1	NR	7/18/24
1,1-Dichloroethylene	< 0.5	7	7/18/24	Dibromomethane	< 0.5	NR	7/18/24
1,1-Dichloropropylene	< 0.5	NR	7/18/24	Dichlorodifluoromethane	< 0.5	NR	7/18/24
1,2,3-Trichlorobenzene	< 0.5	NR	7/18/24	Diethyl ether	< 0.5	NR	7/18/24
1,2,3-Trichloropropane	< 0.5	NR	7/18/24	Diisopropyl Ether (DIPE)	< 0.5	NR	7/18/24
1,2,4-Trichlorobenzene	< 0.5	70	7/18/24	Ethyl Tert-Butyl Ether (ETBE)	< 0.5	NR	7/18/24
1,2,4-Trimethylbenzene	< 0.5	NR	7/18/24	Ethylbenzene	< 0.5	700	7/18/24
1,2-Dibromo - 3- chloropropane	< 0.5	0.2	7/18/24	Hexachlorobutadiene	< 0.5	NR	7/18/24
1,2-Dibromoethane	< 0.5	NR	7/18/24	Isopropylbenzene	< 0.5	NR	7/18/24
1,2-Dichlorobenzene	< 0.5	600	7/18/24	m/p - Xylenes	<1	NR	7/18/24
1,2-Dichloroethane	< 0.5	5	7/18/24	Methyl ethyl ketone (MEK) 2-Butanone	<10	NR	7/28/15
1,2-Dichloropropane	< 0.5	5	7/18/24	Methylene chloride	< 0.5	5	7/18/24
1,3,5-Trimethylbenzene	< 0.5	NR	7/18/24	Methyl-t-butyl-ether (MtBE)	< 0.5	13	7/18/24
1,3-Dichlorobenzene	< 0.5	NR	7/18/24	Napthalene	< 0.5	NR	7/18/24
1,3-Dichloropropane	< 0.5	NR	7/18/24	n-Butylbenzene	< 0.5	NR	7/18/24
1,4-Dichlorobenzene	< 0.5	75	7/18/24	Nitrobenzene	<10	NR	7/28/15
2,2-Dichloropropane	< 0.5	NR	7/28/15	n-Propylbenzene	< 0.5	NR	7/19/22
2-Butanone (MEK)	<10	NR	7/28/15	o-Xylene	< 0.5	NR	7/18/24
2-Chlorotoluene	<0.5	0.5	1/3/24	sec Butylbenzene	< 0.5	NR	7/18/24
2-Hexanone	<10	NR	7/28/15	Styrene	< 0.5	100	7/18/24
4 Methyl-2-Pentanone (MIBK)	<10	NR	7/28/15	Tert-Amyl Methyl Ether (TAME)	< 0.5	NR	7/18/24
4-Chlorotoluene	<0.5	0.5	1/3/24	Tert-Butyl Alcohol (TBA)	<10	NR	7/18/24
4-Isopropyltoluene	< 0.5	NR	1/3/24	Tert-Butylbenzene	< 0.5	NR	7/18/24
Acetone	<10	NR	7/28/15	Tetrachloroethylene	< 0.5	5	7/18/24
Benzene	< 0.5	5	7/18/24	Tetrachloromethane	< 0.5	NR	7/18/24
Bromobenzene	< 0.5	NR	7/18/24	Tetrahydrofuran	<10	NR	7/18/24
Bromochloromethane	< 0.5	NR	7/18/24	Toluene	< 0.5	1000	7/18/24
Bromodichloromethane	4.3	80	7/18/24	Total Trihalomethanes	22	80	7/18/24
Bromoform	<0.5	80	7/18/24	Total Xylenes	< 0.5	10,000	7/18/24
Bromomethane	< 0.5	NR	7/18/24	Trans-1, 2-Dichloroethylene	< 0.5	100	7/18/24
Carbon Disulfide	< 0.5	NR	7/18/24	Trans-1, 3-Dichloropropylene	< 0.5	NR	7/18/24
Carbon Tetrachloride	< 0.5	5	7/18/24	Trichloroethylene	< 0.5	5	7/18/24
Chlorobenzene	< 0.5	100	7/18/24	Trichlorofluoromethane	< 0.5	NR	7/18/24
Chloroethane	<0.5	NR	7/28/15	Vinyl chloride	< 0.5	2	7/18/24

SYNTHETIC ORGANIC CONTAMINANTS (b) (Units µg/L)

Analyte	Results	MCL	Date	Analyte	Results	MCL	Date
2,4,5-TP (Silvex)	< 0.25	50	7/18/24	Diquat	<1	20	7/18/24
2,4-D	< 1	70	7/18/24	Endrin	< 0.1	2	7/18/24
3-Hydroxycarbofuran	< 1	NR	7/18/24	Ethylene dibromide (EDB)	< 0.02	0.05	7/18/24
Alachlor	< 0.1	2	7/18/24	Glyphosate	< 10	700	7/18/24
Aldicarb	< 1	NR	7/18/24	Heptachlor	< 0.1	0.4	7/18/24
Aldicarb Sulfone	< 1	NR	7/18/24	Heptachlor Epoxide	< 0.1	0.2	7/18/24
Aldicarb Sulfoxide	< 1	NR	7/18/24	Hexachlorobenzene	< 0.1	1	7/18/24
Aldrin	< 0.1	NR	7/18/24	Hexachlorocyclopentadiene	< 0.1	50	7/18/24
Atrazine	< 0.1	3	7/18/24	Lindane	< 0.1	0.2	7/18/24
Benzo(a)pyrene	< 0.1	0.2	7/18/24	Methiocarb	< 1	7	7/18/24
Butachlor	< 0.1	NR	7/18/24	Methomyl	< 1	NR	7/18/24
Carbaryl	< 1	NR	7/18/24	Methoxychlor	< 0.1	40	7/18/24
Carbofuran	< 1	40	7/18/24	Metolachlor	< 0.1	40	7/18/24
Chlordane	< 0.4	2	7/18/24	Metribuzin	< 0.1	NR	7/18/24
Di (2-ethylhexyl) adipate	< 1	400	7/18/24	Oxamyl (Vydate)	< 1	200	7/18/24
Di (2-Ethylhexyl) phthalate	< 1	6	7/18/24	Pentachlorophenol	< 0.1	1	7/18/24
Dibromochloropropane (DBCP)	< 0.02	0.2	7/28/15	Picloram	<2	500	7/18/24
Dicamba	< 0.5	NR	7/18/24	Propachlor	< 0.1	NR	7/18/24
Dieldrin	< 0.1	NR	7/18/24	Propoxur (Baygon)	< 1	NR	7/18/24
Dinoseb	< 1	7	7/18/24	Simazine	< 0.1	4	7/18/24
				Toxaphene	< 2	3	7/18/24

RADIOLOGICAL CONTAMINANTS (b)

Analyte (Units)	Results	MCL	Date
Compliance Gross Alpha (pCi/L)	5.6±1.0	15	9/5/18
Radium 226 & 228 (pCi/L)	<1	5	9/5/18
Uranium (µg/L)	< 1	30	7/18/24

FIRST DRAW LEAD AND COPPER (a)

Analyte	Results	AL	Date
Lead (µg/L) 90th percentile sample	0	15	2022
Copper (mg/L) 90th percentile sample	0.200	1.3	2022

WATER QUALITY REPORT
Sweet Hill, Plaistow, NH
EPA # 1932200

INORGANIC CONTAMINANTS (b)

Analyte	Results	MCL	Date
Antimony (mg/L)	<0.001	0.006	7/18/24
Arsenic (mg/L)	0.0011	0.01	7/18/24
Barium (mg/L)	0.0296	2	7/18/24
Beryllium (mg/L)	<0.001	0.004	7/18/24
Cadmium (mg/L)	<0.001	0.005	7/18/24
Chromium (mg/L)	0.0014	0.1	7/18/24
Fluoride (mg/L)	0.35	4	7/18/24
Mercury (mg/L)	<0.0001	0.002	7/18/24
Nitrate-N (mg/L)	<0.2	10	7/18/24
Nitrite-N (mg/L)	< 0.2	1	7/18/24
Selenium (mg/L)	<0.001	0.05	7/18/24
Thallium (mg/L)	<0.001	0.002	7/18/24
Cyanide (mg/L)	<0.005	0.2	7/18/24

SECONDARY CONTAMINANTS (b) - AESTHETIC

Analyte	Results	SMCL	Date
Chloride (mg/L)	42	250	7/18/24
Fluoride (mg/L)	0.35	2	7/18/24
Iron (mg/L)	0.033	0.3	7/18/24
Manganese (mg/L)	0.0103	0.05	7/18/24
pH (Standard Units)	7.79	6.5 – 8.5	7/18/24
Sulfate (mg/L)	23	250	7/18/24
Zinc (mg/L)	0.0372	5	7/18/24

Microbiological Contaminants (a)

Results	MCL	Frequency
Total Coliform	Absent ≤ 1/month	Monthly
E. coli	Absent	Monthly
Chlorine Residual Range (mg/L)	0.2 - 1.0	

DISINFECTION BY-PRODUCTS (a)

Analyte	Results	MCL	Date
Total Trihalomethanes (µg/L)	19	80	7/2/24
Haloacetic Acids (µg/L)	26	60	7/2/24

UNREGULATED CONTAMINANTS (b)

Analyte (Units)	Results	Date
Alkalinity as CaCO ₃ (mg/L)	91	7/18/24
Calcium (mg/L)	21.3	7/18/24
Copper (mg/L)	0.0151	7/18/24
Hardness, Total as CaCO ₃ (mg/L)	76.3	7/18/24
Magnesium (mg/L)	5.6	7/18/24
Nickel (µg/L)	<0.001	7/18/24
Radon Gas (pCi/L)	962	8/8/23
Sodium (mg/L)	41.7	7/18/24

Perfluorinated Chemicals (PFCs)

Analyte (Units)	Results	MCL	Date
Hexafluoropropylene oxide dimer acid (HFPO-DA) (ng/L)	<2.00	NR	5/19/23
Perfluorobutanesulfonic acid (PFBS) (ng/L)	<2.00	NR	5/19/23
Perfluorohexanesulfonic acid (PFHxS) (ng/L)	<2.00	18	5/19/23
Perfluorononanoic acid (PFNA) (ng/L)	<2.00	11	5/19/23
Perfluorooctanesulfonic acid (PFOS) (ng/L)	<2.00	15	5/19/23
Perfluorooctanoic acid (PFOA) (ng/L)	<2.00	12	5/19/23

SOURCE WATER AND TREATMENT INFORMATION

Water Source: Two bedrock wells

Treatment: chlorine for disinfection, polyphosphate for corrosion control while also sequestering metals. In winter, a calcite filter is used for pH adjustment.

KEY TO ABBREVIATIONS

AL Action Level - The concentration of a contaminant which, if exceeded triggers treatment of or other requirements which a water system must follow.

MCL Maximum Contaminant Level - The highest level of a contaminant that is allowed in drinking water.

SMCL Secondary Maximum Contaminant Level – These standards are developed to protect the aesthetic qualities of drinking water and are not health based characteristics (taste, odor, or color) of drinking water.

NR Not Regulated - Contaminants test for but not regulated by the State or EPA.

(a) samples taken from the distribution system.

(b) samples taken from the distribution entry point.

mg/L milligrams per Liter or parts per million.

µg/L micrograms per Liter or parts per billion.

ng/L nanograms per Liter or parts per trillion.

pCi/L picocuries per Liter (measure of radioactivity)

N/A Not Applicable **nd** not detected **BDL** Below Detection Level ≤ Less Than or Equal To < Less Than

CONTACT INFORMATION

If you have any questions about this report, or about your water quality, please call Matthew Day, Water Supply Manager, at 1-603-913-2377 or 1-800-553-5191.

Additional information about contaminants and their potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline 1-800-426-4791.

WATER QUALITY REPORT
Sweet Hill, Plaistow, NH
EPA # 1932200

Additional information can be found on the State's website:
<http://www2.des.state.nh.us/DESONestop/PWSDetail.aspx?ID=1932200>