

Consumer Confidence Report

Pittsfield

EPA # 1911010

2021

What is a Consumer Confidence Report?

The Consumer Confidence Report (CCR) details the quality of your drinking water, where it comes from, and where you can get more information. This annual report documents all detected primary and secondary drinking water parameters, and compares them to their respective standards known as Maximum Contaminant Levels (MCLs).

NOW IT COMES WITH A LIST OF INGREDIENTS.



The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.

Inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.

Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.

Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also, come from gas stations, urban storm water runoff, and septic systems.

Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the EPA prescribes regulations which limit the amounts of certain contaminants in water provided by public water systems. The US Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

What is the source of my drinking water?

The water supply source for the Town of Pittsfield is Berry Pond, located off Route 107 in Pittsfield, NH. Water flows from Berry Pond into Berry Brook and then into the holding pond next to the treatment plant. Water flows from the holding pond into the treatment plant. Treatment consists of flocculation, sedimentation, filtration, chlorination for disinfection, pH adjustment, and zinc ortho-phosphate addition for control corrosion.

Why are contaminants in my water?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Do I need to take special precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline at 1-800-426-4791.

Source Water Assessment Summary

Department of Environmental Service (DES) prepared drinking water source assessment reports for all public water systems between 2000 and 2003 in an effort to assess the vulnerability of each of the state's public water supply sources. Included in the report is a map of each source water protection area, a list of potential and known contamination sources, and a summary of available protection options.

Source Name	Date	Low	Med	High
Berry Pond	10/28/02	8	3	1

Note: This information is over 18 years old and includes information that was current at the time the report was completed. Therefore, some of the ratings might be different if updated to reflect current information. At the present time, DES has no plans to update this data.

The complete Assessment Report is available for review. For more information, call *Matt Day* at 800-553-5191 or visit the DES Drinking Water Source Assessment website at <https://www.des.nh.gov/climate-and-sustainability/conservation-mitigation-and-restoration/source-water-protection/assessment>

How can I get involved?

For more information about your drinking water, please call our laboratory at 800-553-5191 or send an email to customer-service@pennichuck.com. Although we do not have specific dates for public participation events or meetings, feel free to contact us with any questions you may have.

Violations: We are pleased to announce there were no violations.

Health Effects

Lead: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. This water system is responsible for high quality drinking water, but cannot control the variety of materials used in your plumbing components. **When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing cold water from your tap for at least 30 seconds before using water for drinking or cooking.** Do not use hot water for drinking and cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://water.epa.gov/drink/info/lead/index.cfm>.

Definitions

Action Level or AL: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level or MCL: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal or MCLG: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Definitions

Maximum Residual Disinfectant Level or MRDL:

The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal or MRDLG:

The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Treatment Technique or TT: A required process intended to reduce the level of a contaminant in drinking water.

Turbidity: A measure of the cloudiness of the water. It is monitored by surface water systems because it is a good indicator of water quality and thus helps measure the effectiveness of the treatment process. High turbidity can hinder the effectiveness of disinfectants.

Secondary Maximum Contaminant Level or SMCL:

They identify acceptable concentrations of contaminants which cause unpleasant tastes, odors, or colors in the water.

Abbreviations

NA: Not Applicable

ND: Not Detectable at testing limits

NTU: Nephelometric Turbidity Unit

pCi/L: picoCurie per Liter

ppb: parts per billion

ppm: parts per million

RAA: Running Annual Average

90th Percentile – Out of every 10 homes sampled, 9 were at or below this level

Data 2020

Turbidity	TT	Lowest Monthly % of Samples	Highest Detected Daily Value	Violation Yes/No	Typical Source of Contaminant
Daily Compliance (NTU)	5	-----	0.10 – 04/10/20	No	Soil Runoff
Monthly Compliance*	At least 95%	100% -All of 2020	-----	No	
Turbidity is a measure of the cloudiness of the water. We monitor it because it is a good indicator of water quality.					
*Monthly turbidity compliance is related to a specific treatment technique (TT). Our system filters the water so at least 95% of our samples each month must be below the turbidity limits specified in the regulations.					

Year Collected	Highest Detect	Range Detected	MCL	MCLG	Violation Yes/No	Typical Source of Contaminant	
Total Organic Carbon (ppm)	2020	Average 1.27	1.08 – 1.55	TT	NA	No	Naturally present in the environment

The value reported under Amount Detected for TOC is the lowest ratio between the percentage of TOC actually removed to the percentage of TOC required to be removed. A value of >1 indicates that the water system is in compliance with TOC removal requirements.

Year Collected	90 th Percentile	Action Level	MCLG	# of Sites Sampled	# Sites above Action Level	Violation Yes/No	Typical Source of Contaminant	
Lead (ppb)	2018	5	15	0	12	0	No	Corrosion of household plumbing system
Copper (ppm)	2018	0.127	1.3	1.3	12	0	No	Corrosion of household plumbing systems, erosion of natural deposits; leaching from wood preservatives

Inorganic Contaminants	Year Collected	Highest Detect	Range Detected	MCL	MCLG	Violation Yes/No	Typical Source of Contaminant
Barium (ppm)	2020	0.0051	NA	2	2	No	Geological; oil/gas drilling, painting, industrial waste
Synthetic Organic Contaminants including Pesticides and Herbicides							
Ethylene Dibromide (EDB) (ppt)	2020	0.23	NA	50	0	No	Discharge from petroleum refineries
Disinfectants and Disinfection By-Products							
Chlorine (ppm)	Monthly 2020	Monthly Average 0.87	0.66 – 1.06	4-MRDL	4-MRDLG	No	Water additive used to control microbes
Total Trihalomethanes (ppb)	Quarterly 2020	RAA 59.8	33.0 – 99.0	80	0	No	By-product of drinking water chlorination
Haloacetic Acids (ppb)	Quarterly 2020	RAA 22.3	11.0 – 35.0	60	0	No	By-product of drinking water chlorination

Secondary Contaminants					
Secondary MCLs (SMCL)	Level Detected	Date	Treatment technique (if any)	AL (Action Level), SMCL or AGQS (Ambient groundwater quality standard)	Specific contaminant criteria and reason for monitoring
Chloride (ppm)	7	2020	N/A	250	Wastewater, road salt, water softeners, corrosion
Hardness (ppm)	4.2	2020	N/A	N/A	Geological
Manganese (ppb)	28.4	2020	N/A	50	Geological
pH (SU)	7.37	2020	pH adjustment	6.5-8.5	Precipitation and geology
Sodium (ppm)	8.5	2020	N/A	100-250	Road salt, septic systems (salt from water softeners) We are required to regularly sample for sodium
Sulfate (ppm)	8	2020	N/A	250	Naturally occurring
Zinc (ppm)	0.386	2020	N/A	5	Galvanized pipes