

June 1, 2016

**Litchfield/R&B Water System**  
**PFOA Update**

To our Litchfield and R&B Water System Customers:

Pennichuck promised it would update you regarding significant new information as it became available about the PFOA situation, as it pertains to your water system. Since we provided our last written communication to you, please be advised of the following significant developments:

1. The United States Environmental Protection Agency established a lifetime exposure health advisory for the combination of Perfluorooctanoic Acids (“PFOA”) and Perfluorooctanesulfonic (“PFOS”) of 70 parts per trillion (“ppt”) on May 20, 2016.
2. Your water supply comes from a combination of three wells in southern Litchfield and from the Pennichuck water treatment plant in Nashua.
2. Based upon the testing regime we have instituted related to this situation, the combined levels of PFOA and PFOS in the water being delivered into the Litchfield and R&B Water Systems from the water supplies feeding your water system are as follows:

<b>Date Collected</b>	<b>Date Results Received</b>	<b>PFOA Results (ppt)</b>	<b>PFOA + PFOS Results (ppt)</b>
3/16/2016	3/20/2016	7/9	7/9
4/13/2016	5/11/2016	12	12
5/16/2016	5/23/2016	8	8
5/16/2016	5/23/2016	8	8

If you have any questions regarding these updates, please do not hesitate to contact us.

Sincerely,



Larry D. Goodhue  
Chief Executive Officer