



PENNICHUCK®

25 Walnut Street
PO Box 428
Nashua, NH 03061-0428

(800) 553-5191
Fax (603) 913-2362
customer-service@pennichuck.com

SUPPLEMENTAL SPECIFICATION

March 7, 2023

AMENDMENT TO PENNICHUCK TECHNICAL SPECIFICATIONS (October 20, 2021)

1. Water Main Pipe and Fittings, SECTION 01600 C-1.c: add the following as an option to the ISO 8179-1 Zinc Coated pipe as described in paragraphs 2-4 of this section

Standard asphalt -coated (minimum 4 mil exterior thickness) Class 52 ductile iron pipe will be allowed when the pipe is encased in V-Bio Enhanced Polyethylene encasement or an equivalent polyethylene product. Refer to manufacturer's requirements and Pennichuck Technical Specification Section 01625 D for installation of polyethylene encasement.

This Amendment and added language above will expire on December 31, 2023.
On January 1, 2024 the ISO 8179-1 Zinc Coated Class 52 ductile iron pipe specification will be in effect again as the only ductile iron pipe accepted.

End of Amendment