

**PENNICHUCK WATER WORKS**

| Sample Site Location            | Date Collected | Date Results Received | PFOA Results (ppt) | PFOS Results (ppt) | PFNA | PFHxS | PFOA + PFOS Results (ppt) |
|---------------------------------|----------------|-----------------------|--------------------|--------------------|------|-------|---------------------------|
| WTP-Lab Finished Water Tap      | 7/16/2014      | n/a                   | < 20               | < 40               |      |       | < 20                      |
| WTP-Lab Finished Water Tap      | 10/15/2014     | n/a                   | < 20               | < 40               |      |       | < 20                      |
| WTP-Lab Finished Water Tap      | 1/12/2015      | n/a                   | < 20               | < 40               |      |       | < 20                      |
| WTP-Lab Finished Water Tap      | 4/17/2015      | n/a                   | < 20               | < 40               |      |       | < 20                      |
| WTP-Lab Finished Water Tap      | 3/16/2016      | 3/20/2016             | 3.00               | <40                |      |       | 3.0                       |
| Harris Pond- Lab Tap            | 3/16/2016      | 3/20/2016             | 9.00               | <40                |      |       | 9.0                       |
| Merrimack River- Intake Station | 3/17/2016      | 4/14/2016             | 2.10               | < 4.4              |      |       | 2.1                       |
| WTP-Lab Finished Water Tap      | 4/13/2016      | 5/11/2016             | 5.80               | 8.40               |      |       | 14.2                      |
| WTP-Lab Finished Water Tap      | 5/19/2016      | 5/27/2016             | < 2                | < 4                |      |       | < 4                       |
| WTP-Lab Finished Water Tap      | 5/19/2016      | 6/27/2016             | 2.60               | < 4.6              |      |       | 2.6                       |
| WTP-Lab Finished Water Tap      | 5/19/2016      | 5/27/2016             | 4.00               | < 4                |      |       | 4.0                       |
| WTP-Lab Finished Water Tap      | 6/15/2016      | 6/24/2016             | 2.00               | < 4                |      |       | 2.0                       |
| WTP-Lab Finished Water Tap      | 7/12/2016      | 7/21/2016             | 3.00               | < 4                |      |       | 3.0                       |
| WTP-Lab Finished Water Tap      | 1/17/2017      | 1/25/2017             | 7.00               | < 4                |      |       | 7.0                       |
| WTP-Lab Finished Water Tap      | 4/11/2017      | 4/24/2017             | 6.00               | < 4                |      |       | 6.0                       |
| WTP-Lab Finished Water Tap      | 7/10/2017      | 8/2/2017              | 12.7               | 2.1                |      |       | 14.8                      |
| WTP-Lab Finished Water Tap      | 10/3/2017      | 10/24/2017            | 9.35               | <1.78              |      |       | 9.4                       |
| WTP-Lab Finished Water Tap      | 1/4/2018       | 1/24/2018             | 13.50              | 1.94               |      |       | 15.4                      |
| WTP-Lab Raw Water Tap           | 1/4/2018       | 1/24/2018             | 17.60              | 3.31               |      |       | 20.9                      |
| Holt Pond Dam-Raw Water         | 1/4/2018       | 1/24/2018             | 22.30              | 3.68               |      |       | 26.0                      |
| WTP-Lab Finished Water Tap      | 2/23/2018      | 3/12/2018             | 12.20              | 2.02               |      |       | 14.2                      |
| WTP-Lab Raw Water Tap           | 2/23/2018      | 3/12/2018             | 13.60              | 2.86               |      |       | 16.5                      |
| Holt Pond Dam-Raw Water         | 2/23/2018      | 3/12/2018             | 12.00              | 2.46               |      |       | 14.5                      |
| WTP-Lab Finished Water Tap      | 3/20/2018      | 4/6/2018              | 8.46               | <1.78              |      |       | 8.5                       |
| Holt Pond Dam-Raw Water         | 3/20/2018      | 4/6/2018              | 10.30              | 2.22               |      |       | 12.5                      |
| WTP-Lab Raw Water Tap           | 3/20/2018      | 4/6/2018              | 6.67               | 3.43               |      |       | 10.1                      |
| WTP-Lab Finished Water Tap      | 4/9/2018       | 4/20/2018             | 9.71               | 1.94               |      |       | 11.7                      |
| Holt Pond Dam-Raw Water         | 4/9/2018       | 4/20/2018             | 13.60              | 3.60               |      |       | 17.2                      |
| WTP-Lab Raw Water Tap           | 4/9/2018       | 4/20/2018             | 10.10              | 2.35               |      |       | 12.5                      |
| WTP-Lab Finished Water Tap      | 5/7/2018       | 5/21/2018             | 9.82               | 2.67               |      |       | 12.5                      |
| Holt Pond Dam-Raw Water         | 5/7/2018       | 5/21/2018             | 15.50              | 4.27               |      |       | 19.8                      |
| WTP-Lab Raw Water Tap           | 5/7/2018       | 5/21/2018             | 10.90              | 3.65               |      |       | 14.6                      |
| Holt Pond Dam-Raw Water         | 6/14/2018      | 7/6/2018              | 19.10              | 7.73               |      |       | 26.8                      |
| WTP-Lab Raw Water Tap           | 6/14/2018      | 7/6/2018              | 17.20              | 4.98               |      |       | 22.2                      |
| WTP-Lab Finished Water Tap      | 6/14/2018      | 7/6/2018              | 15.00              | 3.18               |      |       | 18.2                      |
| Merrimack River- Intake Station | 6/14/2018      | 7/6/2018              | 4.28               | 1.81               |      |       | 6.1                       |
| Holt Pond Dam-Raw Water         | 7/10/2018      | 7/30/2018             | 28.40              | 11.30              |      |       | 39.7                      |
| WTP-Lab Raw Water Tap           | 7/10/2018      | 7/30/2018             | 12.30              | 4.83               |      |       | 17.1                      |
| WTP-Lab Finished Water Tap      | 7/10/2018      | 7/30/2018             | 16.60              | 4.29               |      |       | 20.9                      |
| Merrimack River- Intake Station | 7/10/2018      | 7/30/2018             | 3.96               | <1.78              |      |       | 4.0                       |
| Holt Pond Dam-Raw Water         | 8/14/2018      | 9/11/2018             | 30.10              | 6.69               |      |       | 36.8                      |
| Merrimack River- Intake Station | 8/14/2018      | 9/11/2018             | 3.89               | 1.92               |      |       | 5.8                       |
| WTP-Lab Raw Water Tap           | 8/14/2018      | 9/11/2018             | 13.10              | 6.13               |      |       | 19.2                      |
| WTP-Lab Finished Water Tap      | 8/14/2018      | 9/11/2018             | 15.90              | 3.41               |      |       | 19.3                      |
| Holt Pond                       | 10/1/2018      | 10/11/2018            | 14.80              | 3.5                |      |       | 18.34                     |
| Holt Pond                       | 10/1/2018      | 10/11/2018            | 15.80              | 2.4                |      |       | 18.20                     |
| Merrimack River- Intake Station | 10/1/2018      | 10/11/2018            | 3.59               | <1.78              |      |       | 3.59                      |
| Merrimack River- Intake Station | 10/1/2018      | 10/11/2018            | 3.92               | <1.82              |      |       | 3.92                      |
| WTP-Lab Raw Water Tap           | 10/1/2018      | 10/11/2018            | 18.20              | 4.2                |      |       | 22.40                     |
| WTP-Lab Finished Water Tap      | 10/1/2018      | 10/11/2018            | 13.60              | 2.8                |      |       | 16.43                     |
| Holt Pond                       | 11/27/2018     | 12/13/2018            | 12.70              | 3.2                |      |       | 15.90                     |
| Holt Pond                       | 11/27/2018     | 12/13/2018            | 13.60              | 6.6                |      |       | 17.20                     |

|                                 |            |            |       |       |       |       |       |
|---------------------------------|------------|------------|-------|-------|-------|-------|-------|
| Merrimack River- Intake Station | 11/27/2018 | 12/13/2018 | 4.84  | <1.80 |       |       | 4.84  |
| Merrimack River- Intake Station | 11/27/2018 | 12/13/2018 | 4.98  | <1.78 |       |       | 4.98  |
| WTP-Lab Raw Water Tap           | 11/27/2018 | 12/13/2018 | 13.20 | 2.6   |       |       | 15.8  |
| WTP-Lab Finished Water Tap      | 11/27/2018 | 12/13/2018 | 12.20 | <1.78 |       |       | 12.2  |
| Holt Pond                       | 12/26/2018 | 1/10/2019  | 13.60 | 2.7   |       |       | 16.3  |
| Merrimack River- Intake Station | 12/26/2018 | 1/10/2019  | 2.11  | <1.84 |       |       | 2.11  |
| WTP-Lab Raw Water Tap           | 12/26/2018 | 1/10/2019  | 13.70 | 2.0   |       |       | 15.7  |
| WTP-Lab Finished Water Tap      | 12/26/2018 | 1/10/2019  | 11.30 | <1.77 |       |       | 11.3  |
| Holt Pond                       | 1/8/2019   | 1/25/2019  | 14.90 | 3.0   |       |       | 17.9  |
| Merrimack River- Intake Station | 1/8/2019   | 1/25/2019  | 3.02  | <1.84 |       |       | 3.02  |
| WTP-Lab Raw Water Tap           | 1/8/2019   | 1/25/2019  | 13.60 | 3.1   |       |       | 16.7  |
| WTP-Lab Finished Water Tap      | 1/8/2019   | 1/25/2019  | 11.70 | 2.0   |       |       | 13.7  |
| Holt Pond                       | 2/4/2019   | 2/15/2019  | 14.40 | 2.5   |       |       | 16.9  |
| Merrimack River- Intake Station | NOT TAKEN  |            |       |       |       |       |       |
| WTP-Lab Raw Water Tap           | 2/4/2019   | 2/15/2019  | 13.90 | 2.4   |       |       | 16.3  |
| WTP-Lab Finished Water Tap      | 2/4/2019   | 2/15/2019  | 13.70 | <1.84 |       |       | 13.7  |
| Holt Pond                       | 3/5/2019   | 3/19/2019  | 11.90 | 2.1   |       |       | 14.02 |
| Merrimack River- Intake Station | 3/5/2019   | 3/19/2019  | 2.80  | <1.77 |       |       | 2.8   |
| WTP-Lab Raw Water Tap           | 3/5/2019   | 3/19/2019  | 11.40 | 2.2   |       |       | 13.6  |
| WTP-Lab Finished Water Tap      | 3/5/2019   | 3/19/2019  | 9.95  | <1.76 |       |       | 9.95  |
| Holt Pond                       | 4/2/2019   | 4/12/2019  | 11.50 | 2.3   |       |       | 13.8  |
| Holt Pond                       | 5/8/2019   | 5/22/2019  | 11.90 | 3.0   |       |       | 14.9  |
| Merrimack River- Intake Station | 5/7/2019   | 5/22/2019  | 2.42  | <1.74 |       |       | 2.42  |
| WTP-Lab Raw Water Tap           | 5/7/2019   | 5/22/2019  | 12.60 | 3.0   |       |       | 15.6  |
| WTP-Lab Finished Water Tap      | 5/7/2019   | 5/22/2019  | 12.80 | 3.1   |       |       | 15.9  |
| Holt Pond                       | 6/3/2019   | 6/17/2019  | 18.80 | 5.1   |       |       | 23.9  |
| Merrimack River- Intake Station | 6/3/2019   | 6/17/2019  | 3.84  | <1.82 |       |       | 3.84  |
| WTP-Lab Raw Water Tap           | 6/3/2019   | 6/17/2019  | 16.40 | 7.5   |       |       | 23.9  |
| WTP-Lab Finished Water Tap      | 6/3/2019   | 6/17/2019  | 15.50 | 3.5   |       |       | 19    |
| Holt Pond                       | 7/9/2019   | 7/25/2019  | 20.00 | 4.4   |       |       | 24.4  |
| Merrimack River- Intake Station | 7/10/2019  | 7/24/2019  | 3.96  | <1.71 |       |       | 3.96  |
| WTP-Lab Raw Water Tap           | 7/9/2019   | 7/25/2019  | 12.50 | 2.5   |       |       | 15    |
| WTP-Lab Finished Water Tap      | 7/9/2019   | 7/25/2019  | 11.30 | 2.2   |       |       | 13.5  |
| Holt Pond                       | 8/1/2019   | 8/16/2019  | 19.40 | 5.3   |       |       | 24.7  |
| Merrimack River- Intake Station | 8/1/2019   | 8/16/2019  | 4.47  | 2.1   |       |       | 6.57  |
| WTP-Lab Raw Water Tap           | 8/1/2019   | 8/16/2019  | 16.80 | 4.1   |       |       | 20.9  |
| WTP-Lab Finished Water Tap      | 8/1/2019   | 8/16/2019  | 9.23  | 1.8   |       |       | 11    |
| Holt Pond                       | 8/21/2019  | 9/9/2019   | 23.40 | 7.1   |       |       | 30.5  |
| Merrimack River- Intake Station | 8/21/2019  | 9/9/2019   | 4.00  | <1.82 |       |       | 4     |
| WTP-Lab Raw Water Tap           | 8/21/2019  | 9/9/2019   | 4.29  | <1.72 |       |       | 4.29  |
| WTP-Lab Finished Water Tap      | 8/21/2019  | 9/9/2019   | 7.85  | <1.73 |       |       | 7.85  |
| Holt Pond                       | 9/3/2019   | 9/20/2019  | 27.60 | 6.2   |       |       | 33.8  |
| Merrimack River- Intake Station | 9/3/2019   | 9/20/2019  | 5.50  | <1.84 |       |       | 5.5   |
| WTP-Lab Raw Water Tap           | 9/3/2019   | 9/20/2019  | 5.87  | 2.4   |       |       | 8.29  |
| WTP-Lab Finished Water Tap      | 9/3/2019   | 9/20/2019  | 7.30  | <1.73 |       |       | 7.3   |
| Holt Pond                       | 10/1/2019  | 10/23/2019 | 25.30 | 8.6   | <1.75 | 5.05  | 33.93 |
| Merrimack River- Intake Station | 10/1/2019  | 10/23/2019 | 4.84  | <1.75 | <1.75 | <1.75 | 4.84  |
| WTP-Lab Raw Water Tap           | 10/1/2019  | 10/23/2019 | 4.78  | <1.78 | <1.78 | <1.78 | 4.78  |
| WTP-Lab Finished Water Tap      | 10/1/2019  | 10/23/2019 | 6.61  | <1.75 | <1.75 | <1.75 | 6.61  |
| Holt Pond                       | 11/4/2019  | 12/11/2019 | 23.60 | 3.8   | <2.0  | 2.28  | 27.4  |
| Merrimack River- Intake Station | 11/4/2019  | 12/11/2019 | <2.0  | <2.0  | <2.0  | <2.0  | <2.0  |
| WTP-Lab Raw Water Tap           | 11/4/2019  | 12/11/2019 | 17.50 | 2.9   | <2.0  | 2.42  | 20.43 |
| WTP-Lab Finished Water Tap      | 11/4/2019  | 12/11/2019 | 2.74  | <2.0  | <2.0  | <2.0  | 2.74  |
| Holt Pond                       | 12/17/2019 | 1/23/2020  | 10.50 | 2.5   | <2.0  | <2.0  | 13.04 |
| Merrimack River- Intake Station | NOT TAKEN  |            |       |       |       |       |       |
| WTP-Lab Raw Water Tap           | 12/17/2019 | 1/23/2020  | 15.90 | 2.9   | <2.0  | <2.0  | 18.82 |

|                                 |            |            |       |       |       |       |       |
|---------------------------------|------------|------------|-------|-------|-------|-------|-------|
| WTP-Lab Finished Water Tap      | 12/17/2019 | 1/23/2020  | 5.66  | <2.0  | <2.0  | <2.0  | 5.66  |
| Holt Pond                       | 1/9/2020   | 2/3/2020   | 11.20 | 2.0   | <2.0  | <2.0  | 13.21 |
| Merrimack River- Intake Station | NOT TAKEN  |            |       |       |       |       |       |
| WTP-Lab Raw Water Tap           | 1/9/2020   | 2/3/2020   | 12.30 | 2.7   | <2.0  | <2.0  | 14.95 |
| WTP-Lab Finished Water Tap      | 1/9/2020   | 2/3/2020   | 4.63  | <2.0  | <2.0  | <2.0  | 4.63  |
| Holt Pond                       | 2/26/2020  | 3/10/2020  | 12.20 | 3.4   | <2.0  | <2.0  | 15.6  |
| Merrimack River- Intake Station | 2/12/2020  | 3/10/2020  | 3.04  | <2.0  | <2.0  | <2.0  | 3.04  |
| WTP-Lab Raw Water Tap           | 2/26/2020  | 3/10/2020  | 10.80 | 3.3   | <2.0  | <2.0  | 14.14 |
| WTP-Lab Finished Water Tap      | 2/26/2020  | 3/10/2020  | 4.46  | <2.0  | <2.0  | <2.0  | 4.46  |
| Holt Pond                       | 3/12/2020  | 3/20/2020  | 13.80 | 3.3   | <2.0  | 2.12  | 17.07 |
| Merrimack River- Intake Station | 3/12/2020  | 3/20/2020  | <2.0  | <2.0  | <2.0  | <2.0  | <2.0  |
| WTP-Lab Raw Water Tap           | 3/12/2020  | 3/20/2020  | 9.05  | <2.0  | <2.0  | <2.0  | 9.05  |
| WTP-Lab Finished Water Tap      | 3/12/2020  | 3/20/2020  | 4.47  | <2.0  | <2.0  | <2.0  | 4.47  |
| Holt Pond                       | 4/1/2020   | 4/7/2020   | 10.30 | 2.4   | <2.0  | <2.0  | 12.7  |
| Merrimack River- Intake Station | 4/1/2020   | 4/7/2020   | <2.0  | <2.0  | <2.0  | <2.0  | <2.0  |
| WTP-Lab Raw Water Tap           | 4/1/2020   | 4/7/2020   | <2.0  | <2.0  | <2.0  | <2.0  | <2.0  |
| WTP- Kitchen Sink               | 4/1/2020   | 4/7/2020   | 2.28  | <2.0  | <2.0  | <2.0  | 2.28  |
| Holt Pond                       | 5/4/2020   | 5/13/2020  | 12.10 | 3.7   | <2.0  | <2.0  | 15.8  |
| Merrimack River- Intake Station | 5/4/2020   | 5/13/2020  | <2.0  | <2.0  | <2.0  | <2.0  | <2.0  |
| WTP-Lab Raw Water Tap           | 5/4/2020   | 5/13/2020  | <2.0  | <2.0  | <2.0  | <2.0  | <2.0  |
| WTP-Lab Finished Water Tap      | 5/4/2020   | 5/13/2020  | <2.0  | <2.0  | <2.0  | <2.0  | <2.0  |
| Holt Pond                       | 6/8/2020   | 6/15/2020  | 22.10 | 7.44  | <1.75 | 3.33  | 29.54 |
| Merrimack River- Intake Station | 6/8/2020   | 6/15/2020  | 3.28  | <1.78 | <1.78 | <1.78 | 3.28  |
| WTP-Lab Raw Water Tap           | 6/8/2020   | 6/15/2020  | 7.01  | 2.32  | <1.76 | <1.76 | 9.33  |
| WTP-Lab Finished Water Tap      | 6/17/2020  | 7/2/2020   | 2.20  | <1.74 | <1.74 | <1.74 | 2.2   |
| Holt Pond                       | 7/6/2020   | 7/17/2020  | 25.00 | 6.7   | <1.82 | 3.53  | 31.73 |
| Merrimack River- Intake Station | 7/6/2020   | 7/17/2020  | 3.03  | <1.80 | <1.80 | <1.80 | 3.03  |
| WTP-Lab Raw Water Tap           | 7/6/2020   | 7/17/2020  | 15.60 | 4.5   | <1.77 | 2.02  | 20.14 |
| WTP-Lab Finished Water Tap      | 7/6/2020   | 7/17/2020  | 2.02  | <1.77 | <1.77 | <1.77 | 2.02  |
| Holt Pond                       | 8/10/2020  | 8/21/2020  | 19.70 | 9.2   | <1.73 | 3.78  | 28.86 |
| Merrimack River- Intake Station | 8/10/2020  | 8/21/2020  | 3.72  | 2.1   | <1.79 | <1.79 | 5.79  |
| WTP-Lab Raw Water Tap           | 8/10/2020  | 8/21/2020  | 20.20 | 6.3   | <1.74 | 2.67  | 26.45 |
| WTP-Lab Finished Water Tap      | 8/10/2020  | 8/21/2020  | 3.47  | <1.81 | <1.81 | <1.81 | 3.47  |
| Holt Pond                       | 9/14/2020  | 9/30/2020  | 20.30 | 11.3  | <2.0  | 4.82  | 31.6  |
| Merrimack River- Intake Station | 9/14/2020  | 9/30/2020  | 4.36  | <2.0  | <2.0  | <2.0  | 4.36  |
| WTP-Lab Raw Water Tap           | 9/14/2020  | 9/30/2020  | 9.32  | 4.0   | <2.0  | 2.25  | 13.35 |
| WTP-Lab Finished Water Tap      | 9/14/2020  | 9/30/2020  | 2.32  | <2.0  | <2.0  | <2.0  | 2.32  |
| Holt Pond                       | 10/5/2020  | 10/20/2020 | 18.90 | 15.8  | <2.0  | 6.50  | 34.7  |
| Merrimack River- Intake Station | 10/5/2020  | 10/20/2020 | 3.53  | <2.0  | <2.0  | <2.0  | 3.53  |
| WTP-Lab Raw Water Tap           | 10/5/2020  | 10/20/2020 | 5.12  | 2.38  | <2.0  | <2.0  | 7.5   |
| WTP-Lab Finished Water Tap      | 10/5/2020  | 10/20/2020 | 2.19  | <2.0  | <2.0  | <2.0  | 2.19  |
| Holt Pond                       | 11/16/2020 | 12/16/2020 | 24.40 | 6.19  | <2.00 | 3.15  | 30.6  |
| Merrimack River- Intake Station | 11/16/2020 | 12/16/2020 | 2.72  | <2.00 | <2.00 | <2.00 | 2.72  |
| WTP-Lab Raw Water Tap           | 11/16/2020 | 12/16/2020 | 2.30  | <2.00 | <2.00 | <2.00 | 2.30  |
| WTP-Lab Finished Water Tap      | 11/16/2020 | 12/16/2020 | <2.00 | <2.00 | <2.00 | <2.00 | <2.00 |
| Holt Pond                       | 12/1/2020  | 12/18/2020 | 23.20 | 5.32  | <2.00 | <2.00 | 28.50 |
| Merrimack River- Intake Station | 12/1/2020  | 12/18/2020 | 2.43  | <2.00 | <2.00 | <2.00 | 2.43  |
| WTP-Lab Raw Water Tap           | 12/1/2020  | 12/18/2020 | 11.20 | 2.93  | <2.00 | 2.13  | 14.10 |
| WTP-Lab Finished Water Tap      | 12/1/2020  | 12/18/2020 | <2.00 | <2.00 | <2.00 | <2.00 | <2.00 |
| Holt Pond                       | 1/11/2021  | 1/21/2021  | 12.00 | 3.07  | <2.00 | 2.06  | 15.07 |
| Merrimack River- Intake Station | 1/18/2021  | 1/23/2021  | <2.00 | <2.00 | <2.00 | <2.00 | <2.00 |
| WTP-Lab Raw Water Tap           | 1/11/2021  | 1/21/2021  | 12.30 | 3.50  | <2.00 | <2.00 | 15.80 |
| WTP-Lab Finished Water Tap      | 1/11/2021  | 1/21/2021  | <2.00 | <2.00 | <2.00 | <2.00 | <2.00 |
| Holt Pond                       | 2/1/2021   | 2/15/2021  | 13.60 | 2.98  | <2.00 | <2.00 | 16.60 |
| Merrimack River- Intake Station | 2/8/2021   | 2/19/2021  | 2.67  | <2.00 | <2.00 | <2.00 | 2.67  |
| WTP-Lab Raw Water Tap           | 2/1/2021   | 2/15/2021  | 12.60 | 3.88  | <2.00 | <2.00 | 16.50 |

|                                       |           |            |       |       |       |       |       |
|---------------------------------------|-----------|------------|-------|-------|-------|-------|-------|
| WTP-Lab Finished Water Tap            | 2/1/2021  | 2/15/2021  | 6.32  | <2.00 | <2.00 | <2.00 | 6.32  |
| Holt Pond                             | 3/1/2021  | 3/16/2021  | 13.40 | 3.10  | <2.00 | <2.00 | 16.50 |
| Merrimack River- Intake Station       | 3/1/2021  | 3/16/2021  | 2.90  | <2.00 | <2.00 | <2.00 | 2.90  |
| WTP-Lab Raw Water Tap                 | 3/1/2021  | 3/16/2021  | 15.30 | 3.12  | <2.00 | <2.00 | 18.40 |
| WTP-Lab Finished Water Tap            | 3/1/2021  | 3/16/2021  | 2.75  | <2.00 | <2.00 | <2.00 | 2.75  |
| Holt Pond                             | 4/5/2021  | 4/16/2021  | 13.00 | 3.29  | <1.73 | <1.73 | 16.29 |
| Merrimack River- Intake Station       | 4/5/2021  | 4/16/2021  | <1.73 | <1.73 | <1.73 | <1.73 | <1.73 |
| WTP-Lab Raw Water Tap                 | 4/5/2021  | 4/16/2021  | 11.50 | 2.42  | <1.75 | <1.75 | 13.92 |
| WTP-Lab Finished Water Tap            | 4/5/2021  | 4/16/2021  | <1.76 | <1.76 | <1.76 | <1.76 | <1.76 |
| Holt Pond                             | 5/3/2021  | 5/14/2021  | 12.10 | 3.30  | <2.00 | <2.00 | 15.40 |
| Merrimack River- Intake Station       | 5/3/2021  | 5/14/2021  | <2.00 | <2.00 | <2.00 | <2.00 | <2.00 |
| WTP-Lab Raw Water Tap                 | 5/19/2021 | 6/7/2021   | 12.40 | 3.89  | <2.00 | <2.00 | 16.29 |
| WTP-Lab Finished Water Tap            | 5/3/2021  | 5/14/2021  | <2.00 | <2.00 | <2.00 | <2.00 | <2.00 |
| Holt Pond                             | 7/6/2021  | 7/21/2021  | 21.40 | 5.46  | <2.00 | <2.00 | 26.90 |
| WTP-Lab Raw Water Tap                 | 7/6/2021  | 7/21/2021  | 15.60 | 3.99  | <2.00 | <2.00 | 19.59 |
| Merrimack River/ Harris Pond Combined | 7/6/2021  | 7/21/2021  | 2.36  | <2.00 | <2.00 | <2.00 | 2.36  |
| WTP-Lab Finished Water Tap            | 7/6/2021  | 7/21/2021  | 3.87  | <2.00 | <2.00 | <2.00 | 3.87  |
| Holt Pond                             | 8/2/2021  | 8/18/2021  | 18.70 | 4.24  | <2.00 | <2.00 | 22.94 |
| WTP-Lab Raw Water Tap                 | 8/2/2021  | 8/18/2021  | 6.83  | <2.00 | <2.00 | <2.00 | 6.83  |
| Merrimack River- Intake Station       | 8/2/2021  | 8/18/2021  | 2.86  | <2.00 | <2.00 | <2.00 | 2.86  |
| WTP-Lab Finished Water Tap            | 8/2/2021  | 8/18/2021  | 7.86  | <2.00 | <2.00 | <2.00 | 7.86  |
| Holt Pond                             | 9/3/2021  | 9/22/2021  | 24.90 | 4.50  | <2.00 | <2.00 | 29.40 |
| WTP-Lab Raw Water Tap                 | 9/3/2021  | 9/22/2021  | 23.40 | 6.00  | <2.00 | <2.00 | 29.36 |
| WTP-Lab Finished Water Tap            | 9/3/2021  | 9/22/2021  | 11.60 | <2.00 | <2.00 | <2.00 | 11.60 |
| Holt Pond                             | 10/5/2021 | 10/20/2021 | 17.40 | 4.40  | <2.00 | <2.00 | 21.80 |
| WTP-Lab Raw Water Tap                 | 10/5/2021 | 10/20/2021 | 23.85 | 3.85  | <2.00 | <2.00 | 27.75 |
| WTP-Lab Finished Water Tap            | 10/5/2021 | 10/20/2021 | 4.92  | <2.00 | <2.00 | <2.00 | 4.92  |
| Holt Pond                             | 11/8/2021 | 11/23/2021 | 18.30 | 2.89  | <2.00 | <2.00 | 21.20 |
| WTP-Lab Raw Water Tap                 | 11/8/2021 | 11/23/2021 | 20.40 | 3.85  | <2.00 | <2.00 | 24.25 |
| WTP-Lab Finished Water Tap            | 11/8/2021 | 11/23/2021 | 6.12  | <2.00 | <2.00 | <2.00 | 6.12  |
| Holt Pond                             | 12/6/2021 | 12/28/2021 | 19.20 | 3.26  | <2.00 | 2.02  | 22.50 |
| WTP-Lab Raw Water Tap                 | 12/6/2021 | 12/28/2021 | 18.50 | 2.84  | <2.00 | 2.16  | 21.30 |
| WTP-Lab Finished Water Tap            | 12/6/2021 | 12/28/2021 | 3.23  | <2.00 | <2.00 | <2.00 | <2.00 |
| Holt Pond                             | 1/3/2022  | 1/27/2022  | 17.70 | 2.95  | <2.00 | <2.00 | 20.70 |
| WTP-Lab Raw Water Tap                 | 1/3/2022  | 1/27/2022  | 19.70 | 3.29  | <2.00 | <2.00 | 23.00 |
| WTP-Lab Finished Water Tap            | 1/3/2022  | 1/21/2022  | 3.21  | <2.00 | <2.00 | <2.00 | 3.21  |
| Holt Pond                             | 2/22/2022 | 3/11/2022  | 16.50 | 3.73  | <2.00 | <2.00 | 20.20 |
| WTP-Lab Raw Water Tap                 | 2/22/2022 | 3/11/2022  | 13.60 | 2.81  | <2.00 | <2.00 | 16.40 |
| WTP-Lab Finished Water Tap            | 2/22/2022 | 3/11/2022  | 12.00 | <2.00 | <2.00 | <2.00 | 12.00 |
| Holt Pond                             | 3/15/2022 | 4/4/2022   | 13.60 | 3.11  | <2.00 | <2.00 | 16.71 |
| WTP-Lab Raw Water Tap                 | 3/15/2022 | 4/4/2022   | 13.70 | 2.79  | <2.00 | <2.00 | 16.49 |
| WTP-Lab Finished Water Tap            | 3/15/2022 | 4/4/2022   | 5.30  | <2.00 | <2.00 | <2.00 | 5.30  |
| Holt Pond                             | 4/4/2022  | 4/22/2022  | 15.50 | 2.48  | <2.00 | <2.00 | 18.00 |
| WTP-Lab Raw Water Tap                 | 4/4/2022  | 4/22/2022  | 3.39  | <2.00 | <2.00 | <2.00 | 3.39  |
| WTP-Lab Finished Water Tap            | 4/4/2022  | 4/22/2022  | 2.87  | <2.00 | <2.00 | <2.00 | 2.87  |
| Holt Pond                             | 5/2/2022  | 5/26/2022  | 15.60 | 3.26  | <2.00 | <2.00 | 18.90 |
| WTP-Lab Raw Water Tap                 | 5/2/2022  | 5/26/2022  | 10.50 | 2.42  | <2.00 | <2.00 | 12.90 |
| Merrimack River/ Harris Pond Combined | 5/2/2022  | 5/26/2022  | 2.55  | <2.00 | <2.00 | <2.00 | 2.55  |
| WTP-Lab Finished Water Tap            | 5/2/2022  | 5/26/2022  | 3.60  | <2.00 | <2.00 | <2.00 | 3.60  |
| Holt Pond                             | 6/2/2022  | 6/17/2022  | 29.30 | 6.96  | <2.00 | 2.64  | 36.30 |
| WTP-Lab Raw Water Tap                 | 6/2/2022  | 6/17/2022  | 5.80  | 2.21  | <2.00 | <2.00 | 8.01  |
| Merrimack River/ Harris Pond Combined | 6/2/2022  | 6/17/2022  | 4.65  | <2.00 | <2.00 | <2.00 | 4.65  |
| WTP-Lab Finished Water Tap            | 6/2/2022  | 6/17/2022  | 5.98  | <2.00 | <2.00 | <2.00 | 5.98  |
| Holt Pond                             | 7/7/2022  | 7/27/2022  | 30.80 | 9.36  | <2.00 | 3.76  | 40.20 |
| WTP-Lab Raw Water Tap                 | 7/7/2022  | 7/27/2022  | 12.60 | 4.19  | <2.00 | <2.00 | 16.80 |
| Merrimack River/ Harris Pond Combined | 7/7/2022  | 7/27/2022  | 5.75  | 2.26  | <2.00 | <2.00 | 8.05  |

|                                       |           |            |       |       |       |       |       |
|---------------------------------------|-----------|------------|-------|-------|-------|-------|-------|
| WTP-Lab Finished Water Tap            | 7/7/2022  | 7/26/2022  | 8.24  | <2.00 | <2.00 | <2.00 | 8.24  |
| Holt Pond                             | 8/1/2022  | 8/15/2022  | 46.00 | 12.50 | <2.00 | 4.44  | 58.50 |
| WTP-Lab Raw Water Tap                 | 8/1/2022  | 8/15/2022  | 17.10 | 4.10  | <2.00 | 2.20  | 21.80 |
| Merrimack River/ Harris Pond Combined | 8/1/2022  | 8/15/2022  | 5.86  | 2.04  | <2.00 | <2.00 | 7.86  |
| WTP-Lab Finished Water Tap            | 8/1/2022  | 8/15/2022  | 7.57  | <2.00 | <2.00 | <2.00 | 7.57  |
| Holt Pond                             | 9/7/2022  | 9/26/2022  | 27.60 | 16.40 | <2.00 | 3.71  | 44.00 |
| WTP-Lab Raw Water Tap                 | 9/7/2022  | 9/26/2022  | 6.96  | 3.09  | <2.00 | <2.00 | 10.06 |
| Merrimack River/ Harris Pond Combined | 9/7/2022  | 9/26/2022  | 6.08  | 3.04  | <2.00 | <2.00 | 9.08  |
| WTP-Lab Finished Water Tap            | 9/7/2022  | 9/26/2022  | 6.33  | <2.00 | <2.00 | <2.00 | 6.33  |
| Holt Pond                             | 10/4/2022 | 10/24/2022 | 29.60 | 9.09  | <2.00 | 3.88  | 38.69 |
| WTP-Lab Raw Water Tap                 | 10/4/2022 | 10/24/2022 | 12.20 | <2.00 | <2.00 | <2.00 | 12.20 |
| Merrimack River/ Harris Pond Combined | 10/4/2022 | 10/24/2022 | 21.60 | 6.47  | <2.00 | 2.22  | 28.10 |
| WTP-Lab Finished Water Tap            | 10/4/2022 | 10/24/2022 | 10.60 | <2.00 | <2.00 | <2.00 | 10.60 |
| Holt Pond                             | 11/1/2022 | 11/21/2022 | 28.20 | 7.10  | <2.00 | 2.49  | 35.30 |
| WTP-Lab Raw Water Tap                 | 11/1/2022 | 11/21/2022 | 2.72  | <2.00 | <2.00 | <2.00 | 2.72  |
| Merrimack River/ Harris Pond Combined | 11/1/2022 | 11/21/2022 | 2.13  | <2.00 | <2.00 | <2.00 | 2.33  |
| WTP-Lab Finished Water Tap            | 11/1/2022 | 11/21/2022 | 3.25  | <2.00 | <2.00 | <2.00 | 3.25  |
| Holt Pond                             | 12/9/2022 | 1/16/2023  | 18.40 | 4.19  | <2.00 | <2.00 | 22.60 |
| WTP-Lab Raw Water Tap                 | 12/9/2022 | 1/16/2023  | <2.00 | <2.00 | <2.00 | <2.00 | <2.00 |
| Merrimack River/ Harris Pond Combined | 12/9/2022 | 1/16/2023  | <2.00 | <2.00 | <2.00 | <2.00 | <2.00 |
| WTP-Lab Finished Water Tap            | 12/9/2022 | 1/16/2023  | 2.07  | <2.00 | <2.00 | <2.00 | <2.00 |
| Holt Pond                             | 1/16/2023 | 2/10/2023  | 10.60 | 2.50  | <2.00 | <2.00 | 13.10 |
| WTP-Lab Raw Water Tap                 | 1/16/2023 | 2/10/2023  | 11.00 | 2.90  | <2.00 | <2.00 | 13.90 |
| Merrimack River/ Harris Pond Combined | 1/16/2023 | 2/10/2023  | <2.00 | <2.00 | <2.00 | <2.00 | <2.00 |
| WTP-Lab Finished Water Tap            | 1/16/2023 | 2/10/2023  | <2.00 | <2.00 | <2.00 | <2.00 | <2.00 |
| WTP-Lab Raw Water Tap                 | 2/2/2023  | 2/22/2023  | 12.00 | 3.02  | <2.00 | <2.00 | 15.02 |
| Merrimack River/ Harris Pond Combined | 2/2/2023  | 2/22/2023  | 2.06  | <2.00 | <2.00 | <2.00 | 2.06  |
| WTP-Lab Finished Water Tap            | 2/2/2023  | 2/22/2023  | <2.00 | <2.00 | <2.00 | <2.00 | <2.00 |
| WTP-Lab Raw Water Tap                 | 3/9/2023  | 3/27/2023  | 11.20 | 3.65  | <2.00 | <2.00 | 14.90 |
| Merrimack River/ Harris Pond Combined | 3/9/2023  | 3/27/2023  | 2.51  | <2.00 | <2.00 | <2.00 | 2.51  |
| WTP-Lab Finished Water Tap            | 3/9/2023  | 3/27/2023  | <2.00 | <2.00 | <2.00 | <2.00 | <2.00 |
| WTP-Lab Raw Water Tap                 | 4/10/2023 | 5/3/2023   | 2.20  | <2.00 | <2.00 | <2.00 | <2.00 |
| Merrimack River/ Harris Pond Combined | 4/10/2023 | 5/3/2023   | <2.00 | <2.00 | <2.00 | <2.00 | <2.00 |
| WTP-Lab Finished Water Tap            | 4/10/2023 | 5/3/2023   | <2.00 | <2.00 | <2.00 | <2.00 | <2.00 |
| WTP-Lab Raw Water Tap                 | 5/2/2023  | 5/29/2023  | 8.29  | 2.54  | <2.00 | <2.00 | 9.79  |
| Merrimack River/ Harris Pond Combined | 5/2/2023  | 5/29/2023  | <2.00 | <2.00 | <2.00 | <2.00 | 2.06  |
| WTP-Lab Finished Water Tap            | 5/2/2023  | 5/29/2023  | <2.00 | <2.00 | <2.00 | <2.00 | <2.00 |
| WTP-Lab Raw Water Tap                 | 6/5/2023  | 6/26/2023  | 4.78  | <2.00 | <2.00 | <2.00 | 4.48  |
| Merrimack River/ Harris Pond Combined | 6/5/2023  | 6/26/2023  | 4.08  | <2.00 | <2.00 | <2.00 | 4.08  |
| WTP-Lab Finished Water Tap            | 6/5/2023  | 6/26/2023  | <2.00 | <2.00 | <2.00 | <2.00 | <2.00 |
| WTP-Lab Raw Water Tap                 | 7/21/2023 | 8/3/2023   | 16.10 | 4.41  | <2.00 | <2.00 | 20.51 |
| Merrimack River/ Harris Pond Combined | 7/21/2023 | 8/3/2023   | 15.70 | 4.77  | <2.00 | <2.00 | 20.47 |
| WTP-Lab Finished Water Tap            | 7/21/2023 | 8/3/2023   | <2.00 | <2.00 | <2.00 | <2.00 | <2.00 |
| WTP-Lab Raw Water Tap                 | 8/16/2023 | 8/31/2023  | 19.90 | 4.85  | <2.00 | <2.00 | 24.75 |
| Merrimack River/ Harris Pond Combined | 8/16/2023 | 8/31/2023  | 3.58  | <2.00 | <2.00 | <2.00 | 3.58  |
| WTP-Lab Finished Water Tap            | 8/16/2023 | 8/31/2023  | <2.00 | <2.00 | <2.00 | <2.00 | <2.00 |