

**PENNICHUCK WATER WORKS**

Sample Site Location	Date Collected	Date Results Received	PFOA Results (ppt)	PFOS Results (ppt)	PFNA	PFHxS	PFOA + PFOS Results (ppt)
WTP-Lab Finished Water Tap	7/16/2014	n/a	< 20	< 40			< 20
WTP-Lab Finished Water Tap	10/15/2014	n/a	< 20	< 40			< 20
WTP-Lab Finished Water Tap	1/12/2015	n/a	< 20	< 40			< 20
WTP-Lab Finished Water Tap	4/17/2015	n/a	< 20	< 40			< 20
WTP-Lab Finished Water Tap	3/16/2016	3/20/2016	3.00	<40			3.0
WTP-Lab Finished Water Tap	4/13/2016	5/11/2016	5.80	8.40			14.2
WTP-Lab Finished Water Tap	5/19/2016	5/27/2016	< 2	< 4			< 4
WTP-Lab Finished Water Tap	5/19/2016	6/27/2016	2.60	< 4.6			2.6
WTP-Lab Finished Water Tap	5/19/2016	5/27/2016	4.00	< 4			4.0
WTP-Lab Finished Water Tap	6/15/2016	6/24/2016	2.00	< 4			2.0
WTP-Lab Finished Water Tap	7/12/2016	7/21/2016	3.00	< 4			3.0
WTP-Lab Finished Water Tap	1/17/2017	1/25/2017	7.00	< 4			7.0
WTP-Lab Finished Water Tap	4/11/2017	4/24/2017	6.00	< 4			6.0
WTP-Lab Finished Water Tap	7/10/2017	8/2/2017	12.7	2.1			14.8
WTP-Lab Finished Water Tap	10/3/2017	10/24/2017	9.35	<1.78			9.4
WTP-Lab Finished Water Tap	1/4/2018	1/24/2018	13.50	1.94			15.4
WTP-Lab Finished Water Tap	2/23/2018	3/12/2018	12.20	2.02			14.2
WTP-Lab Finished Water Tap	3/20/2018	4/6/2018	8.46	<1.78			8.5
WTP-Lab Finished Water Tap	4/9/2018	4/20/2018	9.71	1.94			11.7
WTP-Lab Finished Water Tap	5/7/2018	5/21/2018	9.82	2.67			12.5
WTP-Lab Finished Water Tap	6/14/2018	7/6/2018	15.00	3.18			18.2
WTP-Lab Finished Water Tap	7/10/2018	7/30/2018	16.60	4.29			20.9
WTP-Lab Finished Water Tap	8/14/2018	9/11/2018	15.90	3.41			19.3
WTP-Lab Finished Water Tap	10/1/2018	10/11/2018	13.60	2.8			16.43
WTP-Lab Finished Water Tap	11/27/2018	12/13/2018	12.20	<1.78			12.2
WTP-Lab Finished Water Tap	12/26/2018	1/10/2019	11.30	<1.77			11.3
WTP-Lab Finished Water Tap	1/8/2019	1/25/2019	11.70	2.0			13.7
WTP-Lab Finished Water Tap	2/4/2019	2/15/2019	13.70	<1.84			13.7
WTP-Lab Finished Water Tap	3/5/2019	3/19/2019	9.95	<1.76			9.95
WTP-Lab Finished Water Tap	5/7/2019	5/22/2019	12.80	3.1			15.9
WTP-Lab Finished Water Tap	6/3/2019	6/17/2019	15.50	3.5			19
WTP-Lab Finished Water Tap	7/9/2019	7/25/2019	11.30	2.2			13.5
WTP-Lab Finished Water Tap	8/1/2019	8/16/2019	9.23	1.8			11
WTP-Lab Finished Water Tap	8/21/2019	9/9/2019	7.85	<1.73			7.85
WTP-Lab Finished Water Tap	9/3/2019	9/20/2019	7.30	<1.73			7.3
WTP-Lab Finished Water Tap	10/1/2019	10/23/2019	6.61	<1.75	<1.75	<1.75	6.61
WTP-Lab Finished Water Tap	11/4/2019	12/11/2019	2.74	<2.0	<2.0	<2.0	2.74
WTP-Lab Finished Water Tap	12/17/2019	1/23/2020	5.66	<2.0	<2.0	<2.0	5.66
WTP-Lab Finished Water Tap	1/9/2020	2/3/2020	4.63	<2.0	<2.0	<2.0	4.63

WTP-Lab Finished Water Tap	2/26/2020	3/10/2020	4.46	<2.0	<2.0	<2.0	4.46
WTP-Lab Finished Water Tap	3/12/2020	3/20/2020	4.47	<2.0	<2.0	<2.0	4.47
WTP-Lab Finished Water Tap	5/4/2020	5/13/2020	<2.0	<2.0	<2.0	<2.0	<2.0
WTP-Lab Finished Water Tap	6/17/2020	7/2/2020	2.20	<1.74	<1.74	<1.74	2.2
WTP-Lab Finished Water Tap	7/6/2020	7/17/2020	2.02	<1.77	<1.77	<1.77	2.02
WTP-Lab Finished Water Tap	8/10/2020	8/21/2020	3.47	<1.81	<1.81	<1.81	3.47
WTP-Lab Finished Water Tap	9/14/2020	9/30/2020	2.32	<2.0	<2.0	<2.0	2.32
WTP-Lab Finished Water Tap	10/5/2020	10/20/2020	2.19	<2.0	<2.0	<2.0	21.1
WTP-Lab Finished Water Tap	11/16/2020	12/16/2020	<2.00	<2.00	<2.00	<2.00	<2.00
WTP-Lab Finished Water Tap	12/1/2020	12/18/2020	<2.00	<2.00	<2.00	<2.00	<2.00
WTP-Lab Finished Water Tap	1/11/2021	1/21/2021	<2.00	<2.00	<2.00	<2.00	<2.00
WTP-Lab Finished Water Tap	2/1/2021	2/15/2021	6.32	<2.00	<2.00	<2.00	6.32
WTP-Lab Finished Water Tap	3/1/2021	3/16/2021	2.75	<2.00	<2.00	<2.00	2.75
WTP-Lab Finished Water Tap	4/5/2021	4/16/2021	<1.76	<1.76	<1.76	<1.76	<1.76
WTP-Lab Finished Water Tap	5/3/2021	5/14/2021	<2.00	<2.00	<2.00	<2.00	<2.00
WTP-Lab Finished Water Tap	7/6/2021	7/21/2021	3.87	<2.00	<2.00	<2.00	3.87
WTP-Lab Finished Water Tap	8/2/2021	8/18/2021	7.86	<2.00	<2.00	<2.00	7.86
WTP-Lab Finished Water Tap	9/3/2021	9/22/2021	11.60	<2.00	<2.00	<2.00	11.6
WTP-Lab Finished Water Tap	10/5/2021	10/20/2021	4.92	<2.00	<2.00	<2.00	4.92
WTP-Lab Finished Water Tap	11/8/2021	11/23/2021	6.12	<2.00	<2.00	<2.00	6.12
WTP-Lab Finished Water Tap	12/6/2021	12/28/2021	3.23	<2.00	<2.00	<2.00	<2.00
WTP-Lab Finished Water Tap	1/3/2022	1/21/2022	3.21	<2.00	<2.00	<2.00	3.21
WTP-Lab Finished Water Tap	2/22/2022	3/11/2022	12.00	<2.00	<2.00	<2.00	12
WTP-Lab Finished Water Tap	3/15/2022	4/4/2022	5.30	<2.00	<2.00	<2.00	5.3
WTP-Lab Finished Water Tap	4/4/2022	4/22/2022	2.87	<2.00	<2.00	<2.00	2.87
WTP-Lab Finished Water Tap	5/2/2022	5/26/2022	3.60	<2.00	<2.00	<2.00	3.6
WTP-Lab Finished Water Tap	6/2/2022	6/17/2022	5.98	<2.00	<2.00	<2.00	5.98
WTP-Lab Finished Water Tap	7/7/2022	7/26/2022	8.24	<2.00	<2.00	<2.00	8.24
WTP-Lab Finished Water Tap	8/1/2022	8/15/2022	7.57	<2.00	<2.00	<2.00	7.57
WTP-Lab Finished Water Tap	9/7/2022	9/26/2022	6.33	<2.00	<2.00	<2.00	6.33
WTP-Lab Finished Water Tap	10/4/2022	10/24/2022	10.60	<2.00	<2.00	<2.00	10.6
WTP-Lab Finished Water Tap	11/1/2022	11/21/2022	3.25	<2.00	<2.00	<2.00	3.25
WTP-Lab Finished Water Tap	12/9/2022	1/16/2023	2.07	<2.00	<2.00	<2.00	<2.00
WTP-Lab Finished Water Tap	1/16/2023	2/10/2023	<2.00	<2.00	<2.00	<2.00	<2.00
WTP-Lab Finished Water Tap	2/2/2023	2/22/2023	<2.00	<2.00	<2.00	<2.00	<2.00
WTP-Lab Finished Water Tap	3/9/2023	3/27/2023	<2.00	<2.00	<2.00	<2.00	<2.00
WTP-Lab Finished Water Tap	4/10/2023	5/3/2023	<2.00	<2.00	<2.00	<2.00	<2.00
WTP-Lab Finished Water Tap	5/2/2023	5/29/2023	<2.00	<2.00	<2.00	<2.00	<2.00
WTP-Lab Finished Water Tap	6/5/2023	6/26/2023	<2.00	<2.00	<2.00	<2.00	<2.00
WTP-Lab Finished Water Tap	7/21/2023	8/3/2023	<2.00	<2.00	<2.00	<2.00	<2.00
WTP-Lab Finished Water Tap	8/16/2023	8/31/2023	<2.00	<2.00	<2.00	<2.00	<2.00
WTP-Lab Finished Water Tap	9/12/2023	9/13/2023	<2.00	<2.00	<2.00	<2.00	<2.00
WTP-Lab Finished Water Tap	10/3/2023	10/4/2023	NT	NT	NT	NT	NT

WTP-Lab Finished Water Tap	11/1/2023	11/20/2023	1.05	<2.0	<2.00	<2.00	1.05
WTP-Lab Finished Water Tap	12/1/2023	12/5/2023	<2.00	<2.00	<2.00	<2.00	<2.00
WTP-Lab Finished Water Tap	1/5/2024	1/9/2024	2.06	0.7	<2.00	<2.00	2.74